

Methodology Information Paper 14: Econometric models

Introduction

In this information paper we review both the Ofwat econometric models and the revised models which include information from Scottish Water.

The paper begins by outlining how the Ofwat models were developed and their relevance to cost efficiency. It goes on to discuss how we developed the revised models, which are specific to Scottish Water. We explain each model in detail, comparing the original Ofwat models and our revised versions. We conclude by explaining our proposed approach at the Strategic Review of Charges 2010-14.

Development of Ofwat's econometric models

The econometric models that are used by Ofwat were originally developed by Ofwat and Professor Mark Stewart of the University of Warwick in the early 1990s. They were used by Ofwat at its 1994 price review. They were then reviewed in the late 1990s, again with input from Professor Mark Stewart, and revised models were used by Ofwat at its 1999 and 2004 price reviews.

We used these models to assess the efficiency of the Scottish water industry in both our 2001 and 2005 price reviews. We have continued to use the Ofwat models to monitor Scottish Water's progress towards achieving its efficiency targets and we publish the results of this analysis in our annual 'Costs and performance report'.

The Ofwat models are also used to monitor the relative efficiency of the companies south of the border on an annual basis. Ofwat publishes the results of this analysis in its annual report 'Water and sewerage service unit costs and relative efficiency'. This annual performance assessment influences the share prices of those water companies whose shares are quoted on the London Stock Exchange.

The purpose of each model is to establish a relationship between the costs reported by the companies and external cost drivers. These cost drivers have a significant impact on costs but are outside the control of the management of the company. By controlling the principal external cost drivers in the models, we can determine relative efficiency with a high degree of accuracy. The cost drivers and explanatory factors used to derive the current suite of models relate to the financial year 2004-05.

The models take different forms and are summarised in Table 1.

Table 1: Summary of econometric models and explanatory factors¹

Model	Model type	Explanatory factors
Water resources and treatment	Linear model for unit cost	Population, number of sources, distribution input, proportion of supplies from rivers ² .
Water distribution	Log unit cost	Population, proportion of total mains length with diameter > 300mm.
Water power	Log linear	Distribution input, average pumping head.
Water business activities	Log linear	Number of billed properties.
Sewer network	Log linear	Sewer length, area, resident population, holiday population.
Large sewage treatment works	Log linear	Total load, use of activated sludge treatment, tight effluent consent for both suspended solids and BOD ₅ . ³
Small sewage treatment works	Unit cost	Works size, works type, load.
Sludge treatment and disposal	Unit cost	Weights of dry solids, disposal route.
Sewerage business activities	Unit cost	Number of billed properties.

Our revision of the Ofwat models

Use of Scottish Water information

The information from Scottish Water that we used to revise the models relates to the financial year 2004-05. Ofwat also used information from the companies in 2004-05 in developing its models. We have made every effort to ensure that we collect information on the same basis. The companies provide the required information in their annual regulatory returns to Ofwat. Scottish Water provided the necessary information to us in its 2005 June Return.

Scottish Water has made good progress in improving the asset and customer information that we use in the modelling. Some issues remain relating to, for example, the information that is provided about how much water is put into the distribution system and the amount of pumping necessary. However we consider that these issues are not material to our assessment of the scope for efficiency.

Removal of PPP

We have excluded information about the costs, number and type of customers served and asset bases of Scottish Water's PPP contracts⁴. This

¹ Ofwat has indicated that it expects to have new models for water resources and treatment and sewage sludge treatment and disposal for its 2009 price review ('New approaches to expenditure and incentives: a discussion paper', Ofwat, May 2007).

² Ofwat replaced this with the proportion of supplies from boreholes in its 2005-06 model.

³ The term BOD₅ in this and other tables refers to the five-day biochemical oxygen demand.

⁴ Public private partnerships (PPPs) deliver a significant proportion of sewerage services in Scotland. See Methodology Information Paper 9.

is because we recognise that Scottish Water cannot control the operating costs at PPP works.

Water service model

Water resources and treatment

This model predicts the costs associated with water resources, the treatment process and the operating environment. Specifically, it takes into account economies of scale at water source level and the extra costs of treatment resulting from the proportion of supplies that are taken from rivers. Costs per head are modelled rather than volumetric unit costs. This is to avoid rewarding high leakage or penalising companies that have minimised demand.

Table 2 sets out the statistical details of the model developed by Ofwat using information from the English and Welsh companies and our revised model developed using information from England and Wales and additional information from Scottish Water. We set out the details of each of the models in the same way.

Table 2: Original Ofwat model and our revised model for water resources and treatment operating expenditure

Water resources and treatment				
	Ofwat model		Water Industry Commission for Scotland (WICS) model	
Data	June Returns 2005/Ofwat		Annual Return 2004-05	
Modelled cost	Resources and treatment functional expenditure [£m], less power expenditure [£m], less Environment Agency/Scottish Environment Protection Agency charges [£m], divided by resident winter population [millions]			
Explanatory variables:	Coefficient	Standard error	Coefficient	Standard error
Constant	2.069	2.142	2.046	2.077
Number of sources divided by distribution input [Ml/day]	18.481	7.278	18.468	7.095
Proportion of supplies derived from rivers	4.128	2.734	4.170	2.637
Statistical indicators	R squared	0.256		0.256
	Standard error	2.297		2.239
	Model significance (F test)	0.060		0.052
	Observations	22		23
Form of the model (WICS)	Modelled cost = 2.046 + 18.468 x <u>number of sources</u> + 4.170 x (proportion of supply distribution input from rivers)			

Water distribution

This model uses the ratio of the length of large mains to small mains as the cost driver (see Table 3). Repairs, maintenance and inspection of large mains are likely to incur much greater costs than those on small mains. The model also reflects the higher costs of operating in urban areas, where the density of underground services and traffic congestion can impair productivity. The unit costs are again expressed per head of population, rather than by volume of water. This reduces the potential to penalise companies with low leakage and/or low demand.

Table 3: Original Ofwat model and our revised model for water distribution operating expenditure

Water distribution					
		Ofwat model		WICS model	
Data		June Returns 2005/Ofwat		Annual Return 2004-05	
Modelled cost⁵		ln (distribution functional expenditure excluding power expenditure [£m], divided by resident winter population [000s])			
Explanatory variables:		Coefficient	Standard error	Coefficient	Standard error
Constant		-5.173	0.143	-5.163	0.136
Length of main greater than 300 mm diameter [km] divided by total length of main [km]		5.014	1.807	4.850	1.684
Statistical indicators	R squared	0.278		0.283	
	Standard error	0.200		0.195	
	Model significance (F test)	0.012		0.009	
	Observations	22		23	
Form of the model (WICS)		Modelled cost = -5.163 + 4.850 x $\frac{\text{length of main > 300 mm diameter}}{\text{total length of main}}$			

Water power

This model is based on the physical relationship between the amount of water pumped and the energy required (see Table 4). It incorporates both vertical lift and the energy required to overcome friction in pipes. The model recognises that economies of scale are available through pump maintenance and negotiation of electricity tariffs.

⁵ The term ln in this and other tables is the natural logarithm.

Table 4: Original Ofwat model and our revised model for water power operating expenditure

Water power					
		Ofwat model		WICS model	
Data		June Returns 2005/Ofwat		Annual Return 2004-05	
Modelled cost		ln power expenditure [£m]			
Explanatory variables:		Coefficient	Standard error	Coefficient	Standard error
Constant		-8.794	0.298	-8.817	0.291
ln (distribution input [Ml/day] multiplied by average pumping head [metres])		0.926	0.028	0.928	0.027
Statistical indicators	R squared	0.983		0.983	
	Standard error	0.169		0.166	
	Model significance (F test)	0.000		0.000	
	Observations	22		23	
Form of the model (WICS)		Modelled cost = $-8.817 + 0.928 \times \ln(\text{distribution input} \times \text{average pumping head})$			

Water business activities

This model relates business activity costs (including customer services, scientific services and the charge for doubtful debts) to the number of billed properties (see Table 5). It recognises that there are economies of scale. Other potential cost drivers, for example the number of complaints, are within the control of management and so are not considered valid explanatory factors.

Table 5: Original Ofwat model and our revised model for water business activities operating expenditure

Water business activities					
		Ofwat model		WICS model	
Data		June Returns 2005/Ofwat		Annual Return 2004-05	
Modelled cost		ln (business activities expenditure [£m] including doubtful debts [£m])			
Explanatory variables:		Coefficient	Standard error	Coefficient	Standard error
Constant		-3.728	0.278	-3.775	0.271
ln of number of billed properties [000s]		0.927	0.043	0.936	0.041
Statistical indicators	R squared	0.959		0.960	
	Standard error	0.242		0.241	
	Model significance (F test)	0.000		0.000	
	Observations	22		23	
Form of the model (WICS)		Modelled cost = $-3.775 + 0.936 \times \ln(\text{number of billed properties})$			

of the discharged effluent required to meet environmental standards. The model exhibits considerable economies of scale in the treatment of sewage at the level of individual works.

Table 7: Original Ofwat model and our revised model for large sewage treatment works operating expenditure

Large sewage treatment works					
		Ofwat model		WICS model	
Data		June Returns 2005/Ofwat		Annual Return 2004-05	
Modelled cost		ln (functional expenditure on sewage treatment at large works [£000s] less Environment Agency/Scottish Environment Protection Agency charges [£000s] less terminal pumping costs [£000s])			
Explanatory variables:		Coefficient	Standard error	Coefficient	Standard error
Constant		-1.738	0.259	-1.636	0.255
ln of total load ⁶ [kg BOD/day]		0.804	0.029	0.794	0.029
Activated sludge ⁷		0.330	0.056	0.304	0.056
Tight effluent consent for both suspended solids and BOD ₅ ⁸		0.100	0.050	0.081	0.050
Statistical indicators	R squared	0.714		0.700	
	Standard error	0.493		0.497	
	Model significance (F test)	0.000		0.000	
	Observations	392		412	
Form of the model (WICS)		Modelled cost = -1.636 + 0.794 x ln (total load) + 0.304 x activated sludge + 0.081 x tight effluent consent for both suspended solids and BOD ₅			

Small sewage treatment works

This model uses average unit costs (see Table 8). This is a necessary simplification given that there are thousands of small sewage treatment works. The cost matrix takes into account the size of the works – there are significant economies of scale – and the type of treatment process.

⁶ Total load in this model is estimated as population equivalent x 120.

⁷ Activated sludge includes secondary and tertiary treatment (variable value is 0 if not used, 1 if used).

⁸ Tight effluent consent is defined as 30 mg/litre or less for suspended solids and 20 mg/litre or less for BOD₅ (variable value is 0 if tight consent does not apply, and 1 if the tight consent does apply).

Table 8: Original Ofwat model and our revised model for small sewage treatment works operating expenditure

Cost of small sewage treatment works										
Data	June Returns 2005/Ofwat		Annual Return 2004-05							
Unit cost model	For each treatment type we compared each company's average annual expenditure (direct costs [£000s], less Environment Agency/Scottish Environment Protection Agency charges [£000s], less sludge costs [£000s], plus general and support costs [£000s]) with each company's estimated expenditure (weighted average industry unit cost multiplied by each company's load [kg BOD ₅ /day]).									
Weighted average industry unit cost £000s/(kg BOD₅/day) – Ofwat model										
Treatment type	Primary secondary	Secondary activated sludge	Secondary biological	Tertiary A1	Tertiary A2	Tertiary A1	Tertiary A2	Sea outfall preliminary	Sea outfall screened	Sea outfall unscreened
Size band 1	0.46	0.81	0.95	1.01	0.72	0.88	1.46	0.59	0.05	0.43
Size band 2	0.18	0.65	0.51	0.63	0.26	0.52	0.61	N/A	N/A	N/A
Size band 3	0.21	0.46	0.29	0.44	0.43	0.35	0.39	0.28	0.06	0.01
Size band 4	0.26	0.22	0.18	0.20	0.27	0.19	0.16	N/A	0.11	0.01
Size band 5	N/A	0.15	0.14	0.16	0.15	0.14	0.12	0.02	N/A	N/A
Observations: 500										
Weighted average industry unit cost £000s/(kg BOD₅/day) – WICS model										
Treatment type	Primary secondary	Secondary activated sludge	Secondary biological	Tertiary A1	Tertiary A2	Tertiary A1	Tertiary A2	Sea outfall preliminary	Sea outfall screened	Sea outfall unscreened
Size band 0	0.83	4.27	3.18	4.78	2.34	3.26	2.02	N/A	N/A	0.11
Size band 1 (Scotland)	0.57	1.76	1.21	1.46	N/A	1.29	0.90	N/A	N/A	0.05
Size band 1 (England & Wales)	0.46	0.81	0.95	1.01	0.72	0.88	1.46	0.59	0.05	0.43
Size band 2	0.19	0.72	0.53	0.64	0.49	0.53	0.60	0.02	N/A	0.05
Size band 3	0.16	0.47	0.30	0.46	0.45	0.36	0.39	0.10	0.06	0.03
Size band 4	0.18	0.22	0.18	0.21	0.27	0.20	0.16	0.02	0.05	0.02
Size band 5	0.05	0.15	0.14	0.16	0.15	0.14	0.12	0.02	N/A	N/A
Observations: 560										

Sludge treatment and disposal

This model compares the costs of sludge treatment and disposal to the volume treated and the possible methods of disposal (see Table 9). The model uses average unit costs across England and Wales. The unit cost approach is again a necessary simplification given the large number of sludge treatment and disposal facilities.

Table 9: Original Ofwat model and our revised model for sludge treatment and disposal operating expenditure

Cost of sludge treatment and disposal		
Data	June Returns 2005 / Ofwat Annual Return 2004-05	
Unit cost model	We used a unit cost approach for modelling the treatment and disposal of sludge. For each disposal route, we compared each company's average annual expenditure (sludge functional expenditure [£000s], less Environment Agency/Scottish Environment Protection Agency charges [£000s]) with each company's estimated costs (weighted average industry unit cost multiplied by each company's load [total tonnes of dry solids]).	
Weighted average industry unit cost £000s/(thousand tonnes of dry solids)		
Disposal route	Ofwat model	WICS model
Farmland – untreated	224.0	224.0
Farmland – conventional	176.9	178.6
Farmland – advanced	230.0	231.5
Incineration	159.8	162.9
Landfill	131.6	133.7
Composted	150.0	150.0
Land reclamation	187.2	193.5
Other	212.3	210.1
Observations	80	88

Sewerage business activities

This model uses an average unit cost per billed property across England and Wales (see Table 10). There are too few sewerage companies of sufficiently different size to allow economies of scale to be estimated.

Table 10: Original Ofwat model and our revised model for sewerage business activities operating expenditure

Sewerage business activities	
Data	
Unit cost model	We used a unit cost approach for modelling business activities, based on the number of billed properties. We compared each company's average annual business activities expenditure (total business activities [£m], plus doubtful debts [£m], divided by the number of billed properties) with the weighted average industry cost.
	Weighted average industry unit cost
Ofwat model (£ per billed property)	12.67
WICS extended model (£ per billed property)	13.02
Number of observations	Ofwat: 10; WICS: 11

Proposed approach 2010-14

For the next price review we propose to continue to use both Ofwat's econometric models and our revised versions. Our assessments of Scottish Water's relative efficiency would take account of the results of these models and our alternative model, described in Methodology Information Paper 15.

In our analysis we would continue to apply appropriate adjustments for special factors and differences in the scope of activities that apply in Scotland. We set out our proposed approach to these adjustments in Methodology Information Paper 16.

Related documents

'Strategic Review of Charges 2002-06', Water Industry Commissioner for Scotland, November 2001.

'The Strategic Review of Charges 2006-10: The draft determination', Volume 6, Water Industry Commissioner for Scotland, June 2005.

'The Strategic Review of Charges 2006-10: The final determination', Water Industry Commission for Scotland, November 2005.